

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveyBuilding Information

Page Last Modified: 06/27/2016

Building Information**1. Name of School District:**

BRIARCLIFF MANOR UFSD

2. SED District 8-Digit BEDS Code:

661402020000

3. Building Name:

Todd Elementary school

4. SED 4-Digit Facility Code:

0002

5. Survey Inspection Date:

11/05/2015

6. Building 911 Address:

45 Ingham Road

7. City:

Briarcliff Manor

8. Zip Code:

10510

9. Certificate of Occupancy Status:

- ☒ A - Annual
☐ T - Temporary
☐ N - None

10. Certificate of Occupancy Expiration Date:

09/01/2016

Building Age, Gross Square Footage and Maintenance Staff**11. Year of Original Building:**

1956

12. Gross square ft. of Building as currently configured:

121,983

13. Number of Floors:

2

14. How many full-time and part-time custodians are employed at the school (or work in the building)?

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Information

Page Last Modified: 06/27/2016

	Count Employees
Full-time custodians:	6
Part-time custodians:	3
Totals:	9.00

Building Ownership and Occupancy Status**15. Building Ownership (check one):**

- ☒ Owned and used by district
- ☐ Owned by District and leased to non-district entity
- ☐ Owned by District, part used by district, part leased to non-district entity
- ☐ Owned by non-district entity and leased to district

16. For which of the following purposes is the building currently used? (check all that apply)

- ☒ Used for student instructional purposes
- ☒ Used for district administration
- ☐ Used for other district purposes
- ☐ Used by other organization(s)

Building Users**17. How many students were registered to receive instruction in this building as of October 1, 2014? (If none, enter "0") and skip to "Program Spaces" section. (Do not include evening class students)**

582

18. Of these registered students, how many receive most of their instruction in:

	Quantity
18a. Permanent instructional spaces (i.e., regular classrooms)	582
18b. Temporary instructional spaces (i.e., portable or demountable classrooms) attached to the building	0
18c. Non-instructional spaces used as instructional spaces	0

18c.1 If the answer is greater than zero, which types of non-instructional spaces were being used for instructional purposes on October 1, 2014? (check all that apply)

- ☐ Cafeteria
- ☐ Gymnasium
- ☐ Administrative Spaces
- ☐ Library
- ☐ Lobby
- ☐ Stairwell
- ☐ Storage space
- ☐ Other (please describe)
- ☒ None

19. Grades Housed:

k-5

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveyBuilding Information

Page Last Modified: 06/27/2016

20. For how many instructional days during the 2013-14 school year (July 1 through June 30, was the building closed due to facilities failures, system malfunctions, structural problems, fire, etc? (if none, enter "0")

0

21. Is the building used for instructional purposes in the summer?

☐ Yes☒ No

22. Have there been renovations or construction in the building during the past 12 months?

☒ Yes☐ No

23. Was major construction/renovation work since 2010 conducted when school was in session?

☐ Yes☒ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Program Spaces

Page Last Modified: 06/27/2016

Program Spaces**24. Number of instructional classrooms:**

62

25. Gross square footage of all instructional classrooms (combined):

55,800.00

26. Other spaces provided: (check all that apply)

- | | | |
|---|---|--|
| <input type="checkbox"/> a. N/A (none) | <input checked="" type="checkbox"/> j. Health Office | <input checked="" type="checkbox"/> s. Resource Rooms |
| <input checked="" type="checkbox"/> b. Administration | <input type="checkbox"/> k. Home & Careers | <input type="checkbox"/> t. Science Labs |
| <input checked="" type="checkbox"/> c. Art | <input checked="" type="checkbox"/> l. Kitchen | <input checked="" type="checkbox"/> u. Special Education |
| <input type="checkbox"/> d. Audio Visual | <input type="checkbox"/> m. Large Group Instruction | <input type="checkbox"/> v. Swimming Pool |
| <input type="checkbox"/> e. Auditorium | <input checked="" type="checkbox"/> n. Library | <input checked="" type="checkbox"/> w. Teacher Resource |
| <input checked="" type="checkbox"/> f. Cafeteria | <input checked="" type="checkbox"/> o. Multipurpose Rooms | <input type="checkbox"/> x. Technology/Shop |
| <input checked="" type="checkbox"/> g. Computer Room | <input checked="" type="checkbox"/> p. Music | <input type="checkbox"/> y. Other (please describe) |
| <input checked="" type="checkbox"/> h. Guidance | <input type="checkbox"/> q. Pre-K | |
| <input checked="" type="checkbox"/> i. Gymnasium | <input checked="" type="checkbox"/> r. Remedial Rooms | |

26y. Describe other spaces

(No Response)

Space Adequacy**27. Rating of space adequacy:**

- ☒ Good
☐ Fair
☐ Poor

27a. Enter comments:

(No Response)

28. Estimated capital construction expenses anticipated for this building through 2020-2021 school year excluding maintenance (to be answered after the building inspection is complete) \$

3,600,000.00

29. Overall building rating (to be answered after the building inspection is complete)

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Poor

30. Was overall building rating established after consultation with health and safety committee?

- ☐ Yes
☒ No

A/E Information:**31. A/E Firm Name:**

Fuller & D'Angelo PC

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveyProgram Spaces

Page Last Modified: 06/27/2016

32. A/E Firm Address:

45 Knollwood Road Suite 401 Elmsford,N.Y. 10523

33. A/E Firm Phone Number:

9145924444

34. E-mail:

johnd@fullerdangelo.com

35. A/E Name:

John D'Angelo

36. A/E License #:

022145

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Site Utilities

Page Last Modified: 06/27/2016

Site Utilities**37. Water**

- ☒ Yes
☐ No

37a. Type of Service:

- ☒ Municipal or Utility provided
☐ Well
☐ Other

37b. Condition:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

37c. Year of Last Major Reconstruction/Replacement:

2002

37d. Expected Remaining Useful Life (Years):

10

37e. Cost to Reconstruct/Replace \$:

(No Response)

37f. Comments:

(No Response)

38. Site Sanitary (H)

- ☒ Yes
☐ No

38a. Type of Service:

- ☒ Municipal or utility sewer
☐ Site septic
☐ Other

38b. Condition:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

38c. Year of Last Major Reconstruction/Replacement:

1995

38d. Expected Remaining Useful Life (Years):

7

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Site Utilities

Page Last Modified: 06/27/2016

38e. Cost to reconstruct/Replace \$:

(No Response)

38f. Comments:

(No Response)

39. Site Gas (H)☒ Yes☐ No**39a. Type of gas service:**☒ Natural Gas☐ Liquid Petroleum**39b. Condition:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure**39c. Year of Last Major Reconstruction/Replacement;**

2002

39d. Expected Remaining Useful Life (Years):

7

39e. Cost to Reconstruct/Replace \$:

(No Response)

39f. Comments:

(No Response)

40. Site Fuel Oil (H)☒ Yes☐ No**40a. Number of Above-Ground Tanks:**

0

40a.1 Capacity of Above-Ground Tanks (gallons):

(No Response)

40b. Number of Below-Ground Tanks:

1

40b.1 Capacity of Below-Ground Tanks (gallons):

10,000

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Site Utilities

Page Last Modified: 06/27/2016

40c. Condition:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure
- ☐ N/A

40d. Year of Last Major Reconstruction/Replacement:

1995

40e. Expected Remaining Useful Life (Years):

10

40f. Cost to Reconstruct/Replace \$:

(No Response)

40g. Comments:

Replace Fill Lines

41. Site Electrical, Including Exterior Distribution (H)

- ☒ Yes
- ☐ No

41a. Service Provider:

- ☒ Municipal or utility provided
- ☐ Self-Generated
- ☐ Other
- ☐ N/A

41b. Type of Service:

- ☐ Above Ground
- ☒ Below Ground
- ☐ N/A

41c. Condition:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

41d. Year of Last Major Reconstruction/Replacement:

2002

41e. Expected Remaining Useful Life (Years):

10

41f. Cost to Reconstruct/Replace \$:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Site Utilities

Page Last Modified: 06/27/2016

41g. Comments:

(No Response)

Stormwater Management**42. Closed Drainage Pipe Stormwater Management System****42a. Does this facility have a closed pipe system?**☒ Yes☐ No**42b. Condition:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure**42c. Year of Last Major Reconstruction/Replacement:**

2002

42d. Expected Remaining Useful Life (Years):

5

42e. Cost to Reconstruct/Replace \$:

26,000.00

42f. Comments:

Add Leaders And Jutters To Modular Classrooms

43. Open Drainage Pipe Stormwater Management System**43a. Does this facility have an open stormwater system (ditch)?**☐ Yes☒ No**44. Catch Basins/Drop Inlets/Manholes****44a. Does this facility have catch basins/drop inlets/manholes?**☒ Yes☐ No**44b. Condition:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Site Utilities

Page Last Modified: 06/27/2016

44c. Year of Last Major Reconstruction/Replacement:

2002

44d. Expected Remaining Useful Life (Years):

3

44e. Cost to Reconstruct/Replace \$:

100,000.00

44f. Comments:

k-1 Courtyard Repair And Replacement To Alleviate Flooding.

45. Culverts**45a. Does this facility have culverts?**☐ Yes☒ No**46. Outfalls****46a. Does this facility have outfalls?**☐ Yes☒ No**47. Infiltration Basins/Chambers****47a. Does this facility have infiltration basins/chambers?**☐ Yes☒ No**48. Retention Basins****48a. Does this facility have retention basins?**☐ Yes☒ No**49. Wetponds****49a. Does this facility have wetponds?**☐ Yes☒ No

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveySite Utilities

Page Last Modified: 06/27/2016

50. Manufactured Stormwater Proprietary Units**50a. Does this facility have proprietary units?**

- ☐ Yes
- ☒ No

51. Point of Outfall Discharge: (check all that apply)

- ☒ Municipal storm sewer system
- ☐ Combined sewer system
- ☐ Surface Water
- ☐ On-site recharge
- ☐ Other (describe)
- ☐ Not Applicable

52. Outfall Reconnaissance Inventory**Were all stormwater outfalls inspected during dry weather for signs of non-stormwater discharge?**

- ☐ Yes
- ☒ No
- ☐ Not Applicable

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Other Site Features

Page Last Modified: 06/27/2016

Other Site Features**53. Pavement (Roadways and Parking Lots)**

- ☒ Yes
☐ No

53a. Type: (check all that apply)

- ☐ Concrete
☒ Asphalt
☐ Gravel
☐ Other
☐ None

53b. Condition:

- ☐ Excellent
☐ Satisfactory
☒ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

53c. Year of Last Major Reconstruction/Replacement:

2002

53d. Expected Remaining Useful Life (Years):

2

53e. Cost to Reconstruct/Replace \$:

1,100,000.00

53f. Comments:

Repave Deteriorated Areas

54. Sidewalks

- ☒ Yes
☐ No

54a. Type: (check all that apply)

- ☒ Concrete
☒ Asphalt
☐ Paver
☐ Other

54b. Condition:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

54c. Year of Last Major Reconstruction/Replacement:

2002

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Other Site Features

Page Last Modified: 06/27/2016

54d. Expected Remaining Useful Life (Years):

3

54e. Cost to Reconstruct/Replace \$:

65,000.00

54f. Comments:

Replace Cracked Sidewalk And Curbs At Front

55. Playgrounds and Playground Equipment☒ Yes☐ No**55a. Condition:**

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

55b. Year of Last Major Reconstruction/Replacement:

2012

55c. Expected Remaining Useful Life (Years):

10

55d. Cost to Reconstruct/Replace \$:

(No Response)

55e. Comments:

(No Response)

56. Athletic Fields and Play Fields☒ Yes☐ No**56a. Condition:**

- ☒ Excellent
- ☐ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

56b. Year of Last Major Reconstruction/Replacement:

2015

56c. Expected Remaining Useful Life (Years):

20

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Other Site Features

Page Last Modified: 06/27/2016

56d. Cost to Reconstruct/Replace \$:

(No Response)

56e. Comments:

(No Response)

56f. Does the facility have synthetic turf field(s)☐ Yes☒ No**56f.1 If Yes, how many synthetic turf fields?**

(No Response)

56f.2 Expected Remaining Useful Life of Synthetic Turf Field(s):

(No Response)

56f.3 Type of synthetic turf field infill:

(No Response)

57. Exterior Bleachers / Stadiums☐ Yes☒ No**58. Related Structures (such as Press Boxes, Dugouts, Climbing Walls, etc.)**☐ Yes☒ No

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveySubstructure

Page Last Modified: 06/27/2016

Substructure**59. Foundation (S)****59a. Type (check all that apply):**

- ☒ Reinforced Concrete
- ☐ Masonry on Concrete Footing
- ☐ Other

59b. Evidence of structural concerns (check all that apply):

- ☐ Structural Cracks
- ☐ Heaving/Jacking
- ☐ Decay/Corrosion
- ☐ Water Penetration
- ☐ Unsupported Ends
- ☐ Other
- ☒ None

59c. Condition:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

59d. Year of Last Major Reconstruction/Replacement:

2002

59e. Expected Remaining Useful Life (Years):

10

59f. Cost to Reconstruct/Replace \$:

(No Response)

59g. Comments:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

BUILDING ENVELOPE**60. Structural Floors (S)****60a. Type (check all that apply):**

- ☒ Reinforced Concrete Slab on Grade
- ☒ Concrete/Metal Deck/Metal Joists
- ☐ Precast Concrete Structural System
- ☐ Wood Deck on Wood Trusses
- ☐ Wood Deck on Wood Joists
- ☐ Concrete Deck on Wood Structure
- ☐ Other (specify)

60b. Evidence of Structural Concerns with Floor Support System (Beams/Joists/Trusses, etc.) (check all that apply):

- ☐ Structural Cracks
- ☐ Unsupported Ends
- ☐ Rot/Decay/Corrosion
- ☐ Deflection
- ☐ Seriously Damaged/Missing Components
- ☐ Other Problems
- ☒ None

60b.1 Describe Other Problems:

(No Response)

60c. Evidence of Structural Concerns with Structural Floor Deck (check all that apply):

- ☐ Cracks
- ☐ Deflection
- ☐ Rot/Decay/Corrosion
- ☒ None

60d. Overall Condition of Structural Floors:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

60e. Year of Last Major Reconstruction/Replacement:

2002

60f. Expected Remaining Useful Life (Years):

10

60g. Cost to Reconstruct/Replace \$:

(No Response)

60h. Comments:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

61. Exterior Walls/Columns (S)**61a. Material (check all that apply):**

- ☐ Concrete
- ☒ Masonry
- ☒ Steel
- ☐ Wood
- ☐ Other (specify)

61b. Evidence of Structural Concerns with Support System (columns, base plates, connections, etc.) (check all that apply):

- ☐ Structural Cracks
- ☐ Rot/Decay/Corrosion
- ☐ Other Problems
- ☒ None

61b.1 Describe Other Problems:

(No Response)

61c. Evidence of Concerns with Exterior Cladding (check all that apply):

- ☐ Cracks/Gaps
- ☐ Inadequate Flashing
- ☒ Efflorescence
- ☐ Moisture Penetration
- ☐ Rot/Decay/Corrosion
- ☐ Other Problems
- ☐ None

61c.1 Describe Other Problems:

(No Response)

61d. Overall Condition of Exterior Walls/Columns:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

61e. Year of Last Major Reconstruction/Replacement:

2002

61f. Expected Remaining Useful Life (Years):

8

61g. Cost to Reconstruct/Replace \$:

(No Response)

61h. Comments:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

62. Chimneys (S)

- ☒ Yes
☐ No

62a. Material (check all that apply):

- ☒ Masonry
☐ Concrete
☐ Metal
☐ Wood
☐ Other

62a.1 Specify other:

(No Response)

62b. Overall Condition of Chimneys:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical failure

62c. Year of Last Major Reconstruction/Replacement:

2002

62.d Expected Remaining Useful Life (Years):

8

62e. Cost to Reconstruct/Replace \$:

(No Response)

62f. Comments:

Remove Old Incinerator Chimney

63. Parapets (S)

- ☐ Yes
☒ No

63f. Comments:

(No Response)

64. Exterior Doors**64a. Overall Condition of Exterior Door Units:**

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

64b. Overall condition of exterior door hardware:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

64c. Do any exterior doors have magnetic locking devices?

- ☐ Yes
- ☒ No

64d. Safety/Security features are adequate?

- ☒ Yes
- ☐ No

64e. Year of Last Major Reconstruction/Replacement:

2015

64f. Expected Remaining Useful Life (Years):

10

64g. Cost to Reconstruct/Replace \$:

(No Response)

64h. Comments:

(No Response)

65. Exterior Steps, Stairs, Ramps (S)

- ☒ Yes
- ☐ No

65a. Overall Condition of Exterior Steps, Stairs and Ramps

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

65b. Year of Last Major Reconstruction/Replacement:

2015

65c. Expected Remaining Useful Life (Years):

3

65d. Cost to Reconstruct/Replace \$:

5,000.00

65e. Comments:

Repair Steps To Kitchen

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

66. Fire Escapes (S)**66a. Does This Facility Have One or More Fire Escapes?**

- ☒ Yes
☐ No

66b. Overall Condition of Fire Escapes

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

66c. Safety features are adequate:

- ☒ Yes
☐ No

66d. Year of Last Major Reconstruction/Replacement:

2002

66e. Expected Remaining Useful Life (Years):

10

66f. Cost to Reconstruct/Replace \$:

(No Response)

66g. Comments:

(No Response)

67. Windows

- ☒ Yes
☐ No

67a. Window Material: (check all that apply)

- ☒ Aluminum
☐ Steel
☐ Vinyl
☐ Solid Wood
☐ Wood w/ External Cladding System
☐ Other

67b. Overall Condition of Windows:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

67c. All Rescue Windows are Operable:

- ☒ Yes
☐ No
☐ N/A

67d. Year of Last Major Reconstruction/Replacement:

2012

67e. Expected Remaining Useful Life (Years):

10

67f. Cost to Reconstruct/Replace \$:

(No Response)

67g. Comments:

(No Response)

Roof and Skylights (S)**68. Roof and Skylights (S)**

- ☒ Yes
☐ No

68a. Type of roof construction (check all that apply):

- ☒ Metal deck on metal trusses/joists
☒ Wood deck on wood trusses/joists
☐ Wood deck on metal trusses/joists
☐ Concrete on metal deck on metal trusses/joists
☐ Other (describe below)

68a.1 Other roof construction type:

(No Response)

68b. Type of roofing material (check all that apply):

- ☒ Single-ply membrane
☐ Built-up
☒ Asphalt shingle
☐ Pre-formed metal
☐ IRMA
☐ Slate
☐ Other (describe below)

68b.1 Other roofing material:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

68c. Evidence of structural concerns with roof support system (beams/joists/trusses, etc.) (check all that apply):

- ☐ Structural cracks
- ☐ Unsupported ends
- ☐ Rot/Decay/Corrosion
- ☐ Deflection
- ☐ Seriously damaged/missing components
- ☐ Other concerns (describe)
- ☒ None

68c.1 Describe other concerns:

(No Response)

68d. Evidence of structural concerns with roof deck (check all that apply):

- ☐ Cracks
- ☐ Deflection
- ☐ Rot/Decay/Corrosion
- ☒ None

68e. Does this facility have skylights?

- ☒ Yes
- ☐ No

68f. Skylight material (check all that apply):

- ☒ Plastic
- ☐ Glass
- ☐ Other
- ☐ N/A

68g. Overall condition of skylights:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

68h. Evidence of concerns with roofing, skylights, flashings, and drains (check all that apply):

- ☐ Failures/Splits/Cracks
- ☐ Rot/Decay/Corrosion
- ☐ Inadequate flashing/curbs/pitch pockets
- ☐ Inadequate or poorly functioning roof drains
- ☐ Evidence of water penetration/active leaks
- ☐ Other (specify)
- ☒ None

68h.1 Specify other concerns:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Building Envelope

Page Last Modified: 06/27/2016

68i. Overall Condition of Roof and Skylights:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

68j. Year of Last Major Reconstruction/Replacement:

2004

68k. Expected Remaining Useful Life (Years):

6

68l. Cost to Reconstruct/Replace \$:

(No Response)

68m. Comments:

Repair/Replace Gym Roof And Flashing

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

INTERIOR SPACES**69. Interior Bearing Walls and Fire Walls (S)**

- ☒ Yes
☐ No

69a. Overall condition of interior bearing walls and fire walls:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-functioning
☐ Critical Failure

69b. Year of Last Major Reconstruction/Replacement:

2002

69c. Expected Remaining Useful Life (Years):

10

69d. Cost to Reconstruct/Replace \$:

(No Response)

69e. Comments:

(No Response)

Other Interior Walls**70. Other Interior Walls**

- ☒ Yes
☐ No

70a. Overall condition of other interior walls:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

70b. Year of Last Major Reconstruction/Replacement:

2002

70c. Expected Remaining Useful Life (Years):

10

70d. Cost to Reconstruct/Replace \$:

(No Response)

70e. Comments:

(No Response)

Floor Finishes

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

71. Carpet

- ☒ Yes
☐ No

71a. Where located (check all that apply):

- ☐ Instructional Space
☒ Common Area

71b. Condition:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

71c. Year of Last Major Reconstruction/Replacement:

2002

71d. Expected Remaining Useful Life (Years):

3

71e. Cost to Reconstruct/Replace \$:

110,000.00

71f. Comments:

Replace Library and k-2 Office Carpet

72. Resilient Tiles or Sheet Flooring

- ☒ Yes
☐ No

72a. Where located (check all that apply):

- ☒ Instructional Space
☒ Common Area

72b. Overall condition of resilient tiles or sheet flooring:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

72c. Year of Last Major Reconstruction/Replacement:

2014

72d. Expected Remaining Useful Life (Years):

5

72e. Cost to Reconstruct/Replace \$:

95,000.00

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

72f. Comments:

Remove VAT In Selected Areas, Replace Damaged VCT. Replace Ramp Tile

73. Hard Flooring (concrete; ceramic tile; stone; etc)

- ☒ Yes
☐ No

73a. Where located (check all that apply):

- ☐ Instructional Space
☒ Common Area

73b. Overall condition of hard flooring:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

73c. Year of Last Major Reconstruction/Replacement:

2014

73d. Expected Remaining Useful Life (Years):

10

73e. Cost to Reconstruct/Replace \$:

(No Response)

73f. Comments:

(No Response)

74. Wood Flooring

- ☒ Yes
☐ No

74a. Where located (check all that apply):

- ☐ Instructional Space
☒ Common Area

74b. Overall condition of wood flooring:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

74c. Year of Last Major Reconstruction/Replacement:

1975

74d. Expected Remaining Useful Life (Years):

5

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

74e. Cost to Reconstruct/Replace \$:

35,000.00

74f. Comments:

Refinish Stage And Gym Floor

Ceilings (H)

75. Ceilings (H)

☒ Yes☐ No

75a. Overall condition of ceilings:

☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure

75b. Year of Last Major Reconstruction/Replacement:

2015

75c. Expected Remaining Useful Life (Years):

8

75d. Cost to Reconstruct/Replace \$:

(No Response)

75e. Comments:

(No Response)

Lockers

76. Lockers

☒ Yes☐ No

76a. Overall condition of lockers:

☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure

76b. Year of Last Major Reconstruction/Replacement:

2002

76c. Expected Remaining Useful Life (Years):

10

76d. Cost to Reconstruct/Replace \$:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

76e. Comments:

(No Response)

Interior Doors**77. Interior Doors**

- ☒ Yes
☐ No

77a. Overall condition of interior door units:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

77b. Overall condition of interior door hardware:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

77c. Year of Last Major Reconstruction/Replacement:

2015

77d. Expected Remaining Useful Life (Years):

5

77e. Cost to Reconstruct/Replace \$:

320,000.00

77f. Comments:

Replace Deteriorated Corridor Doors

Interior Stairs (S)**78. Interior Stairs (S)**

- ☒ Yes
☐ No

78a. Overall condition of interior stairs:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

78b. Year of Last Major Reconstruction/Replacement:

2002

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

78c. Expected Remaining Useful Life (Years):

20

78d. Cost to Reconstruct/Replace \$:

(No Response)

78e. Comments:

(No Response)

Elevator, Lifts and Escalators (H)**79. Elevator, Lift, and Escalators (H)**

- ☒ Yes
☐ No

79a. Overall condition of elevators, lifts, escalators:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

79b. Year of Last Major Reconstruction/Replacement:

2002

79c. Expected Remaining Useful Life (Years):

10

79d. Cost to Reconstruct/Replace \$

(No Response)

79e. Comments:

(No Response)

Interior Electrical Distribution (H)**80. Interior Electrical Distribution (H)**

- ☒ Yes
☐ No

80a. Interior electrical supply meets current needs:

- ☐ Yes
☒ No

80b. Condition of interior electrical distribution:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

80c. Year of Last Major Reconstruction/Replacement:

2002

80d. Expected Remaining Useful Life (Years):

5

80e. Cost to Reconstruct/Replace \$:

45000

80f. Comments:

Upgrade Older Equipment, Add Circuits To Computer Server Rooms

Lighting Fixtures**81. Interior Lighting Fixtures**☒ Yes☐ No**81a. Condition of interior lighting fixtures:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure**81b. Year of Last Major Reconstruction/Replacement:**

2015

81c. Expected Remaining Useful Life (Years):

8

81d. Cost to Reconstruct/Replace \$:

(No Response)

81e. Comments:

(No Response)

Communication Systems (H)**82. Communication Systems (H)**☒ Yes☐ No**82a. Communication systems are adequate:**☒ Yes☐ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Interior Spaces

Page Last Modified: 06/27/2016

82b. Condition of communication systems:

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

82c. Year of Last Major Reconstruction/Replacement:

2002

82d. Expected Remaining Useful Life (Years):

10

82e. Cost to Replace/Reconstruct \$:

(No Response)

82f. Comments:

(No Response)

Swimming Pool and Swimming Pool Systems**83. Swimming Pool and Swimming Pool Systems**

- ☐ Yes
- ☒ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Plumbing (Excluding HVAC Systems)

Page Last Modified: 06/27/2016

PLUMBING**84. Water Distribution System (H)**

- ☒ Yes
☐ No

84a. Types of pipes (check all that apply):

- ☒ Iron
☒ Galvanized
☒ Copper
☐ Lead
☐ PVC
☐ Other

84b. Overall condition of water distribution system:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

84c. Year of Last Major Reconstruction/Replacement:

2014

84d. Expected Remaining Useful Life (Years):

8

84e. Cost to Reconstruct/Replace \$:

(No Response)

84f. Comments:

(No Response)

Plumbing Drainage System (H)**85. Plumbing Drainage System (H)**

- ☒ Yes
☐ No

85a. Types of pipes (check all that apply):

- ☒ Iron
☐ Galvanized
☐ Copper
☐ Lead
☐ PVC
☐ Other

85b. Overall condition of drainage system:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Plumbing (Excluding HVAC Systems)

Page Last Modified: 06/27/2016

85c. Year of Last Major Reconstruction/Replacement:

2014

85d. Expected Remaining Useful Life (Years):

8

85e. Cost to Reconstruct/Replace \$:

(No Response)

85f. Comments:

(No Response)

Hot Water Heaters (H)**86. Hot Water Heaters (H)**☒ Yes☐ No**86a. Type of fuel (check all that apply):**☐ Oil☒ Natural Gas☒ Electricity☐ Propane☐ Other**86b. Overall condition of hot water heaters:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure**86c. Year of Last Major Reconstruction/Replacement:**

2002

86d. Expected Remaining Useful Life (Years):

8

86e. Cost to Reconstruct/Replace \$:

(No Response)

86f. Comments:

(No Response)

Plumbing Fixtures**87. Plumbing Fixtures**☒ Yes☐ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Plumbing (Excluding HVAC Systems)

Page Last Modified: 06/27/2016

87a. Overall condition of plumbing fixtures (including toilets, urinals, lavatories, etc):

- ☐ Excellent
- ☒ Satisfactory
- ☐ Unsatisfactory
- ☐ Non-Functioning
- ☐ Critical Failure

87b. Year of Last Major Reconstruction/Replacement:

2014

87c. Expected Remaining Useful Life (Years):

8

87d. Cost to Reconstruct/Replace \$:

(No Response)

87e. Comments:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

HVAC Systems

Page Last Modified: 06/27/2016

HVAC SYSTEMS**88. HVAC Systems Type****88a. Does this building have a central HVAC system?**

- ☐ Yes
☒ No

Heat Generating Systems (H)**88b.1 Other central HVAC system technology:**

(No Response)

89. Heat Generating Systems (H)

- ☒ Yes
☐ No

89a. Heat generation source (check all that apply):

- ☒ Boiler / Hot Water
☐ Boiler / Steam
☐ Furnace / Forced Air
☐ Unit Ventilation
☐ Geothermal
☐ Biomass
☐ Electric
☐ Other (describe below)

89a.1 Other heat generation source:

(No Response)

89b. Overall condition of heat generating systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

89c. Year of Last Major Reconstruction/Replacement:

2008

89d. Expected Remaining Useful Life (Years):

12

89e. Cost to Reconstruct/Replace \$:

(No Response)

89f. Comments:

(No Response)

Heating Fuel/Energy Systems (H)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

HVAC Systems

Page Last Modified: 06/27/2016

90. Heating Fuel / Energy Systems (H)

- ☐ Yes
☒ No

Cooling/Air Conditioning Generating Systems**91. Cooling / Air-Conditioning Generating Systems**

- ☒ Yes
☐ No

91a. Overall condition of cooling/air-conditioning generating systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

91b. Year of Last Major Reconstruction/Replacement:

2002

91c. Expected Remaining Useful Life (Years):

8

91d. Cost to Reconstruct/Replace \$:

(No Response)

91e. Comments:

(No Response)

AIR HANDLING AND VENTILATION EQUIPMENT**92. Air Handling and Ventilation Equipment: Supply Units, Exhaust Units, Relief/Return Units, etc. (H)**

- ☒ Yes
☐ No

92a. Overall condition of air handling and ventilation systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

92b. Year of Last Major Reconstruction/Replacement:

2002

92c. Expected Remaining Useful Life (Years):

8

92d. Cost to Reconstruct/Replace \$:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

HVAC Systems

Page Last Modified: 06/27/2016

92e. Comments:

(No Response)

Piped Heating and Cooling Distribution Systems**93. Piped Heating and Cooling Distribution Systems: Piping, Pumps, Radiators, Convectorss, Traps, Insulation, etc. (H)**

- ☒ Yes
☐ No

93a. Overall condition of piped heating and cooling distribution systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

93b. Year of Last Major Reconstruction/Replacement:

2002

93c. Expected Remaining Useful Life (Years):

8

93d. Cost to Reconstruct/Replace \$:

(No Response)

93e. Comments:

(No Response)

Ducted Heating and Cooling Distrbution Systems**94. Ducted Heating and Cooling Distribution Systems: Ductwork, Control Dampers, Fire/Smoke Dampers, VAVs, Insulation, etc. (H)**

- ☒ Yes
☐ No

94a. Overall condition of ducted heating and cooling distribution systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

94b. Year of Last Major Reconstruction/Replacement:

2002

94c. Expected Remaining Useful Life (Years):

10

94d. Cost to Reconstruct/Replace \$:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

HVAC Systems

Page Last Modified: 06/27/2016

94e. Comments:

(No Response)

HVAC Control Systems**95. HVAC Control Systems (H)**☒ Yes☐ No**95a. Overall condition of control systems:**☐ Excellent☒ Satisfactory☐ Unsatisfactory☐ Non-Functioning☐ Critical Failure**95b. Year of Last Major Reconstruction/Replacement:**

2002

95c. Expected Remaining Useful Life (Years):

8

95d. Cost to Reconstruct/Replace \$:

(No Response)

95e. Comments:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveyFire Safety Systems

Page Last Modified: 06/27/2016

Fire Safety Systems**96. Fire Alarm Systems (H)**

- ☒ Yes
☐ No

96a. Overall condition of fire alarm system:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

96b. Year of Last Major Reconstruction/Replacement:

2002

96c. Expected Remaining Useful Life (Years):

8

96d. Cost to Reconstruct/Replace \$:

(No Response)

96e. Comments:

(No Response)

Smoke Detection System (H)**97. Smoke Detection Systems (H)**

- ☒ Yes
☐ No

97a. Overall condition of smoke detection systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

97b. Year of Last Major Reconstruction/Replacement:

2002

97c. Expected Remaining Useful Life (Years):

8

97d. Cost to Reconstruct/Replace \$:

(No Response)

97e. Comments:

(No Response)

Fire Suppression Systems

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Fire Safety Systems

Page Last Modified: 06/27/2016

98. Fire Suppression Systems: Sprinklers, Standpipes, Kitchen Hoods, etc. (H)

- ☒ Yes
☐ No

98a. Overall condition of fire suppression systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

98b. Year of Last Major Reconstruction/Replacement:

2000

98c. Expected Remaining Useful Life (Years):

8

98d. Cost to Reconstruct/Replace \$:

(No Response)

98e. Comments:

(No Response)

Emergency/Exit Lighting Systems**99. Emergency / Exit Lighting Systems (H)**

- ☒ Yes
☐ No

99a. Overall condition of emergency / exit lighting systems:

- ☐ Excellent
☒ Satisfactory
☐ Unsatisfactory
☐ Non-Functioning
☐ Critical Failure

99b. Year of Last Major Reconstruction/Replacement:

2015

99c. Expected Remaining Useful Life (Years):

8

99d. Cost to Reconstruct/Replace \$:

(No Response)

99e. Comments;

(No Response)

Emergency/Standby Power Systems

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Fire Safety Systems

Page Last Modified: 06/27/2016

100. Emergency or Standby Power System (H)

☐ Yes

☒ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Accessibility

Page Last Modified: 06/27/2016

ACCESSIBILITY**101. Exterior Accessible Route (H)**

People with disabilities should be able to arrive on site, approach the building, and enter as freely as everyone else. At least one route of travel should be safe and accessible for everyone, including people with disabilities. This route must include handicapped parking, curb cuts, ramps, and automatic door operators as necessary to enter the building.

Is there an accessible exterior route as specified above?

- ☒ Yes
☐ No

102. Interior Accessible Route, Access to Goods and Services, and Restroom Facilities (H)

The layout of the building should allow people with disabilities to obtain materials or services and use the facilities without assistance. This should include access to general purpose and specialized classrooms, public assembly spaces (such as libraries, gymnasiums, auditoriums), nurse's office, main office, and restroom facilities. Services include drinking fountains, telephones, and other amenities.

Is there an accessible interior route as specified above?

- ☒ Yes
☐ No

103. Additional Information on Accessibility

If the building lacks accessible interior or exterior routes:

103a. Cost of improvements needed to provide accessible exterior and interior routes as specified above \$:

(No Response)

103b. Comments:

Ramps Not APA Compliant

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Environment/Comfort/Health

Page Last Modified: 06/27/2016

ENVIRONMENT/COMFORT/HEALTH**104. General Appearance****104a. Overall Rating:**

- ☒ Good
- ☐ Fair
- ☐ Poor

104b. Comments:

(No Response)

105. Cleanliness**105a. Overall Rating:**

- ☒ Good
- ☐ Fair
- ☐ Poor

105b. Comments:

(No Response)

106. Are there walk off mats; grills in the entryway?

- ☒ Yes
- ☐ No

106a. If yes: at least 6 feet long?

- ☒ Yes
- ☐ No

107. Is there noise in classrooms from HVAC units, traffic, etc. that may impact education?

- ☐ Yes
- ☒ No

108. Lighting Quality:**108a. Types of lighting in general purpose classrooms (check all that apply):**

- ☒ Daylight
- ☒ Fluorescent-not full spectrum
- ☐ Fluorescent full spectrum
- ☒ Incandescent
- ☐ Other (describe)

108b. Are there blinds in the classroom to prevent glare?

- ☒ Yes
- ☐ No

108c. Overall Rating:

- ☒ Good
- ☐ Fair
- ☐ Poor

2015 Building Condition Survey Instrument - 2015 Building Conditions SurveyEnvironment/Comfort/Health

Page Last Modified: 06/27/2016

108d. Comments:

(No Response)

109. Evidence of Vermin**109a. Is there evidence of active infestations of...(check all that apply)?**

- ☐ Rodents
- ☐ Wood-boring or Wood-eating Insects
- ☐ Cockroaches
- ☐ Other Vermin
- ☒ None

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Indoor Air Quality

Page Last Modified: 06/27/2016

Indoor Air Quality**110. Mold****110a. Is there visible mold or moldy odors?**

- ☐ Yes
☒ No

110c. Are any surfaces constructed of any of the following materials?

- ☐ Paper-faced or gypsum products
☐ Cellulose products (typically ceiling tiles)

110d. Estimated cost of necessary improvements \$:

(No Response)

110d. Comments:

(No Response)

111. Humidity/Moisture**111a. Overall rating of humidity/moisture condition in building:**

- ☐ Good
☒ Fair
☐ Poor

111b. Are any of the following found in/or around classroom areas (check all that apply)?

- ☐ Active leaks in roof
☐ Active leaks in plumbing
☐ Moisture condensation
☐ Visible stains or water damage
☒ None

111c. Are any of the following found in/or around other areas (check all that apply)?

- ☐ Active leaks in roof
☐ Active leaks in plumbing
☐ Moisture condensation
☐ Visible stains or water damage
☒ None

112. Ventilation: fresh air intake locations, air filters, etc.**112a. Are fresh air intakes near the bus loading, truck delivery, or garbage storage/disposal areas?**

- ☐ Yes
☒ No

112b. Is there accumulated dirt, dust or debris around fresh air intakes?

- ☐ Yes
☒ No

112c. Are fresh air intakes free of blockage?

- ☒ Yes
☐ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Indoor Air Quality

Page Last Modified: 06/27/2016

112d. Is accumulated dirt, dust or debris in ductwork?

- ☐ Yes
☒ No

112e. Are dampers functioning as designed?

- ☒ Yes
☐ No

112f. Condition of air filters:

- ☒ Good
☐ Fair
☐ Poor

112g. Outside air is adequate for occupant load:

- ☒ Yes
☐ No

112h. Rating of ventilation/indoor air quality:

- ☒ Good
☐ Fair
☐ Poor

112i. Comments:

(No Response)

113. Indoor Air Quality (IAQ) Plan**113a. Does the school district use EPA's Tools for Schools program?**

- ☐ Yes
☒ No

113b. If No, is some other IAQ management plan used?

- ☐ Yes
☒ No

113c. Has the District assigned IAQ responsibilities to a designated individual?

- ☐ Yes
☒ No

113c.1 If Yes, what is their job title?

(No Response)

114. Does the school practice IPM?

- ☒ Yes
☐ No

114a. Is vegetation kept one foot away from the building?

- ☒ Yes
☐ No

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

Indoor Air Quality

Page Last Modified: 06/27/2016

114b. Are crevices and holes in walls, floors and pavement sealed or eliminated?

- ☒ Yes
☐ No

114c. Is there a certified pesticide applicator on staff?

- ☐ Yes
☒ No

114d. Are pesticides used in the building?

- ☐ Yes
☒ No

114d.1 If Yes, how are they typically applied?

- ☐ Spot treatment
☐ Area wide treatments

114e. Are pesticides used on the grounds?

- ☐ Yes
☒ No

114e.1 If Yes, was an emergency exemption granted by the Board of Education?

- ☐ Yes
☐ No

115. Does the school have a passive radon mitigation system installed (was built with radon resistant features)?

- ☐ Yes
☒ No

115a. Has the facility been tested for the presence of radon?

- ☐ Yes
☒ No

115b. Were any of the results of the test greater than or equal to 4 picocuries per liter (pCi/L)?

- ☐ Yes
☐ No

115c. If Yes, did the school take steps to mitigate the elevated radon levels?

- ☐ Yes, active mitigation system installed
☐ Yes, passive mitigation system made active
☐ Yes, ventilation controls (HVAC) adjusted
☐ Yes, other (describe)
☐ No action taken

115c.1 Describe other actions taken to mitigate elevated radon levels:

(No Response)

2015 Building Condition Survey Instrument - 2015 Building Conditions Survey

American Red Cross

Page Last Modified: 06/27/2016

American Red Cross Shelter

116. American Red Cross Shelter

☐ Yes

☒ No